



CATALOG NUMBER	CLAMPING RANGE (IN.)	ULTIMATE STRENGTH	DIMENSIONS IN INCHES				
			A	B	C	D	P
FSC-46	.16-.46	16,000	5 <sup>5</sup> / <sub>8</sub>	2	1 <sup>1</sup> / <sub>16</sub>	1/2	5/8
FSC-60	.20-.60	17,000	6 <sup>3</sup> / <sub>8</sub>	2	7/8	1/2	5/8
FSC-70	.30-.70	18,000	6 <sup>3</sup> / <sub>8</sub>	2 <sup>3</sup> / <sub>8</sub>	1 <sup>5</sup> / <sub>16</sub>	1/2	5/8
FSC-83	.40-.83	18,000	6 <sup>3</sup> / <sub>4</sub>	2 <sup>3</sup> / <sub>8</sub>	1	1/2	5/8
FSC-105-N	.40-1.05	25,000	B	2 <sup>3</sup> / <sub>8</sub>	1	1/2	5/8
FSC-119	.70-1.19	25,000	8 <sup>1</sup> / <sub>4</sub>	2 <sup>3</sup> / <sub>4</sub>	1 <sup>1</sup> / <sub>4</sub>	1/2	5/8

NOTES

- 1) BODY & KEEPER : DUCTILE IRON, GRADE 604512, HOT DIP GALV.
- 2) CLEVIS PIN : STEEL, GRADE 5, HOT DIP GALV.
- 3) U-BOLTS & HARDWARE : STEEL, GALV.
- 4) COTTER PIN : STAINLESS STEEL
- 5) BNK SUFFIX INDICATES BOLT, NUT, AND COTTER PIN

CONTINENTAL ELECTRIC COMPANY  
BIRMINGHAM, ALABAMA

IRON SUSPENSION CLAMP

3	ADD. FSC-119	5-25-88	AG
2	ADD. FSC-105-N	2-10-88	L.M.
1	REDRAWN-WAS CEB-1260	4-16-86	JSG
NO.	REVISION	DATE	BY

DRAWN BY: JSG	CHECKED BY: VEP	APPROVED BY: VEP
DATE: 4-16-86		DRAWING NO: CEA-2211