



7801 Park Place Rd. York, SC 29745 USA (803) 628-2100

MPS Catalog Number: Date:	H1 90 10 010 CX SS 005 05/19/2021	
		/19/2021
End Fi	•	
Tower End Fitting:	Gain / 12 d	_
	Anchor / Du	
Line End Fitting:	2 HL Drop Tongue / Du	ictile Iron
Mate	erial	
Corona Ring (Tower):		None
Corona Ring (Line):		None
Corona Rings are recommende	d for applications of 230 kV and above	
Mounting Angle:		12 deg
Number of Sheds:		5
Rod Diameter:		2 in
Weight Estimate:	39.9 lbs	18 kg
Dimension	al Values	
Section Length (L):	20.2 in	513 mm
Rubber Length (X):	10 in	254 mm
Shed spacing (S):	1.6 in	41 mm
Shed Projection (P):	2.7 in	68 mm
Dry Arc Distance:	13 in	330 mm
Leakage Distance:	35.3 in	897 mm
Electrical	s Values	
60 Hz dry Flashover (Min. Withstand):	139 kV	131 kV
60 Hz Wet Flashover (Min. Withstand):	120 kV	89 kV
CIFO Positive (Min. Withstand):	236 kV	205 kV
CIFO Negative (Min. Withstand):	306 kV	237 kV
Mechanica	al Values	
Max. Design Cant. Load (MDCL):	2,713 lbs 1	12.1 kN
Specified Cant. Load (SCL):	5,426 lbs 2	24.1 kN
Specified Tensile Load (STL):	7,000 lbs 3	31.1 kN

This drawing contains confidential information that is the property of MacLean Power, L.L.C. ("MacLean"). Use of MacLean's confidential information without MacLean's express written consent is strictly prohibited and may expose you to legal liability. If you believe that you received this material in error, please destroy it or return it to "MacLean Power, L.L.C., 7801 Park Place Rd., York, South Carolina 29745, USA."





Dimension: inches [millimeters]

NOTE: Drawing not actual depiction of insulator appearance.

Silicone rubber sheath and sheds complies with applicable ANSI and IEC standards.

Notes: