

7801 Park Place Rd. York, SC 29745 USA (803) 628-2100

MPS Catalog Number

## H2 90 10 017 MX SS 009

03/13/2024 Date:

Gain / 12 deg / Steel **Tower End Fitting:** 2 HL Drop Tongue / Galv. Ductile Iron Line End Fitting: **Material** Corona Ring (Line): None Corona Rings are recommended for applications of 230 kV and above 12 deg Mounting Angle: 9 Number of Sheds: 2.5 in Rod Diameter: Weight Estimate: 43.2 lbs 20 kg **Dimensional Values** Section Length (L): 27.8 in 706 mm Rubber Length (X): 17 in 432 mm Shed spacing (S): 1.95 in 50 mm Shed Projection (P): 1.86 in 47 mm Dry Arc Distance: 19.7 in 500 mm 47.9 in Leakage Distance: 1,217 mm

**End Fittings** 

Electricals values					
60 Hz dry Flashover (Min. Withstand):	201	kV	189	kV	
60 Hz Wet Flashover (Min. Withstand):	180	kV	137	kV	
CIFO Positive (Min. Withstand):	340	kV	302	kV	
CIFO Negative (Min. Withstand):	427	kV	336	kV	
Mechanical Values					

Elasteiasia Valuas

Max. Design Cant. Load (MDCL):	3,811	lbs	17 kN
Specified Cant. Load (SCL):	7,622	lbs	33.9 kN
Specified Tensile Load (STL):	15,000	lbs	66.7 kN

This drawing contains confidential information that is the property of MacLean Power, L.L.C. ("MacLean"). Use of MacLean's confidential information without MacLean's express written consent is strictly prohibited and may expose you to legal liability. If you believe that you received this material in error, please destroy it or return it to "MacLean Power, L.L.C., 7801 Park Place Rd., York, South Carolina 29745, USA."

14.0 [356] Ø0.93 12.0 [305] [205] R0.46 x 1.5 SLOT [254] [12 x 38] 0 Ø1.00 MIN. [25.4] R0.50 X .5 SLUT [R12.7 X 12.7]

[50.8]

1.00R

[25,4]

Dimension: inches [millimeters]

NOTE: Drawing not actual depiction of insulator appearance.

Silicone rubber sheath and sheds complies with applicable ANSI and IEC standards.

0.80 MAX.

[20,3]

Notes: