

MPS Catalog Number:

Date:

End Fittings

Tower End Fitting:


Line End Fitting:


7801 Park Place Rd. York, SC 29745 USA (803) 628-2100

H2 90 10 058 CX SS 035 05/20/2021

Gain / 12 deg / Steel Anchor / Ductile Iron 2 HL Drop Tongue / Galv. Ductile Iron

Material			
Corona Ring (Tower):			None
Corona Ring (Line):			None
Corona Rings are recommended for app	lications of 230 kV a	and above	2
Mounting Angle:			12 deg
Number of Sheds:			35
Rod Diameter:			2.5 in
Weight Estimate:	87	lbs	39 kg
Dimensional Val	lues		
Section Length (L):	68	in	1,727 mm
Rubber Length (X):	58	in	1,473 mm
Shed spacing (S):	1.6	in	41 mm
Shed Projection (P):	2.4	in	61 mm
Dry Arc Distance:	60.9	in	1,547 mm
Leakage Distance:	215.5	in	5,474 mm
Electricals Valu	ues		
60 Hz dry Flashover (Min. Withstand):	568	kV	533 kV
60 Hz Wet Flashover (Min. Withstand):	523	kV	418 kV
CIFO Positive (Min. Withstand):	992	kV	878 kV
CIFO Negative (Min. Withstand):	1032	kV	923 kV
Mechanical Val	ues		
Max. Design Cant. Load (MDCL):	1,313	lbs	5.8 kN
Specified Cant. Load (SCL):	2,626	lbs	11.7 kN
Specified Tensile Load (STL):	15,000	lbs	66.7 kN





This drawing contains confidential information that is the property of MacLean Power, L.L.C. ("MacLean"). Use of MacLean's confidential information without MacLean's express written consent is strictly prohibited and may expose you to legal liability. If you believe that you received this material in error, please destroy it or return it to "MacLean Power, L.L.C., 7801 Park Place Rd., York, South Carolina 29745, USA."

Dimension: inches [millimeters]

NOTE: Drawing not actual depiction of insulator appearance.

Silicone rubber sheath and sheds complies with applicable ANSI and IEC standards.

Prepared By: Laurel Wallace