

MPS Catalog Number:

Date:

End Fittings

Tower End Fitting:


Line End Fitting:


7801 Park Place Rd. York, SC 29745 USA (803) 628-2100

H2 90 10 064 AX SS 025 05/20/2021

Gain / 12 deg / Steel Anchor / Ductile Iron 2 HL Drop Tongue / Galv. Ductile Iron

Material				
Corona Ring (Tower):				None
Corona Ring (Line):				None
Corona Rings are recommended for application	ns of 230 kV a	and above		
Mounting Angle:			12	deg
Number of Sheds:			25	
Rod Diameter:			2.5	in
Weight Estimate:	83.3	lbs	38	kg
Dimensional Values				
Section Length (L):	73.8	in	1,875	mm
Rubber Length (X):	64	in	1,626	mm
Shed spacing (S):	2.5	in	64	mm
Shed Projection (P):	2.4	in	61	mm
Dry Arc Distance:	66.9	in	1,699	mm
Leakage Distance:	176.5	in	4,483	mm
Electricals Values				
60 Hz dry Flashover (Min. Withstand):	620	kV	582	kV
60 Hz Wet Flashover (Min. Withstand):	569	kV	457	kV
CIFO Positive (Min. Withstand):	1085	kV	959	kV
CIFO Negative (Min. Withstand):	1121	kV	1006	kV
Mechanical Values				
Max. Design Cant. Load (MDCL):	1,206	lbs	5.4	kN
Specified Cant. Load (SCL):	2,412	lbs	10.7	kN
Specified Tensile Load (STL):	15,000	lbs	66.7	kN





This drawing contains confidential information that is the property of MacLean Power, L.L.C. ("MacLean"). Use of MacLean's confidential information without MacLean's express written consent is strictly prohibited and may expose you to legal liability. If you believe that you received this material in error, please destroy it or return it to "MacLean Power, L.L.C., 7801 Park Place Rd., York, South Carolina 29745, USA."

Dimension: inches [millimeters]

NOTE: Drawing not actual depiction of insulator appearance.

Silicone rubber sheath and sheds complies with applicable ANSI and IEC standards.

Prepared By: Laurel Wallace