

# **Test Data Compilation**



# Spool Insulators J0101, J151

Rev A – 10-06-2020 – Initial Release.

Prepared by

Jessica Mastrofilipo

Spool Insulator Data Compilation



# 1. Introduction

The purpose of this report is to compile all test data for the spool series of insulators into one report. Data is in accordance with ANSI C29.3.

Spool Insulator						
Catalog Number Type Bolt Size ANSI Class						
J0101 Wet Process		5/8"	53-4			
J151	Wet Process	5/8"	53-2			

### 2. Data

#### 2.1 – Dimensional, Visual, and Porosity Requirements

For the visual requirements, insulators are selected at random and inspected for imperfections in the glaze. None were found. These samples were then tested.

J151 Dimensions							
ltom	ANSI C29.3	Measured value (mm)					
item	Requirement	ement Sample 1 Sample 2 Sample 3					
Total Height	76 ± 1.5	76.7	76.4	76.8			
Diameter of Edge	79 ± 3	78.6	78.4	78.2			
Diameter of Hole	18 + 1.5	19	19.3	19.3			
Diameter of side groove	45 ± 3	43.3	43.2	43.5			

#### Table 2: J151 Dimensional Verification – Class 53-2

#### Table 3: J0101 Dimensional Verification – Class 53-4

J0101 Dimensions							
ltom	ANSI C29.3 Measured value			(mm)			
item	Requirement	rement Sample 1 Sample 2 Sample 3	Sample 3				
Total Height	76 ± 1.5	75.7	75.5	76			
Diameter of Edge	105 ± 3	104.2	103.7	103.9			
Diameter of Hole	18 +1.5	19.5	19.4	19.4			
Diameter of side groove	73 ± 3	74.2	73.9	74.1			

For the porosity test, samples were chosen from the broken fragments of the below tensile tests in section 2.3 and tested in accordance with ANSI C29.1. The results for all samples tested passed, and no dye penetrated the body of the dielectric.

# 2.2 – Low Frequency Dry and Wet Flashover Tests

Table 4: J151 Flashover Results - Class 53-2

J151 Low Frequency Dry Flashover							
ANSI C29.3	Sample 1	1 Sampla 2	Sampla 2	AVC	Dace/Fail		
Requirement	Sample 1	Sample 2	Sample S	ΑŬ	r ass/1 all		
95% of 25 kV	26.3 kV	26.4 kV	26.2 kV	26.3 kV	Pass		
J151 Lov	J151 Low Frequency Wet Flashover - Mounted Vertically						
ANSI C29.3	Comple 1	Sample 2	Sample 3	AVG	Pass/Fail		
Requirement	Sample 1						
90% of 12 kV	12.2 kV	11.9 kV	12.4 kV	12.2 kV	Pass		
J151 Low	J151 Low Frequency Wet Flashover - Mounted Horizontally						
ANSI C29.3	Sampla 1	Sample 2	Sample 2		Dace /Eail		
Requirement	sample 1	sample z	sample s	AVG	Pass/Fdll		
90% of 15 kV	15.9 kV	15.3 kV	15.4 kV	15.5 kV	Pass		

#### Table 5: J0101 Flashover Results - Class 53-4

J0101 Low Frequency Dry Flashover							
ANSI C29.3	Comple 1	<b>C 1 1 2</b>	Comple 2				
Requirement	Sample 1	Sample 2	Sample S	AVG	Pass/Fall		
95% of 25 kV	25 kV	25 kV	24.7 kV	24.9 kV	Pass		
J0101 Low Frequency Wet Flashover - Mounted Vertically							
ANSI C29.3	Comple 1	Sample 2	Sample 3	AVG	Pass/Fail		
Requirement	Sample 1						
90% of 12 kV	12.7 kV	12.6 kV	12.6 kV	12.6 kV	Pass		
J0101 Low	J0101 Low Frequency Wet Flashover - Mounted Horizontally						
ANSI C29.3	Comple 1	Comple 2	Comple 2		Decc/Fail		
Requirement	Sample 1	Sample 2	Sample 3	AVG	Pass/Fall		
90% of 15 kV	15.2 kV	15.5 kV	15.1 kV	15.3 kV	Pass		

# 2.3 – Tensile Testing

#### Table 6: J151 Tensile Results - Class 53-2

J151 Tensile Test							
ANSI C29.3 Requirement	Sample 1	Sample 2	Sample 3	Sample 4	Sample 5	Pass/Fail	
13.3 kN	24 kN	21.5 kN	18.5 kN	23 kN	24.5 kN	Pass	



Table 7:	J0101	Tensile	Results	- Class 53-4
----------	-------	---------	---------	--------------

J0101 Tensile Test							
ANSI C29.3 Requirement	Sample 1	Sample 2	Sample 3	Sample 4	Sample 5	Pass/Fail	
20 kN	42.5 kN	38.2 kN	40.4 kN	38.8 kN	42.2 kN	Pass	

# 3. Conclusion

The spool series of insulators are in accordance with ANSI C29.3 requirements.



A. Appendix

Customer Drawing – J151



B. Customer Drawing – J0101

