

MACLEAN POWER SYSTEMS

Reliable Power Products
11411 Addison, Franklin Park, IL 60131 USA (847) 455-0014

	Catalog Number: Date:	END FITTINGS / MATER		\$148054MX01 10/17/2008	
	Tower End Fitting: Line End Fitting:			Y-Clevis all (ANSI 52-5)	
	Corona Ring (tower Corona Ring (line):):		none none	
	Number of Sheds: Weight Estimate:		13.6 Lb	27 s 6.2 kg	
	DIMENSIONAL VALUES				
	Section Length (A): Shed Diameter (B): Shed Spacing (C): Dry Arc Distance: Leakage Distance:		54.3 In 3.7 In 1.57 In 46.1 In 109.2 In	94 mm 40 mm 1,171 mm	
_	ELECTRICAL VALUES				
	60 Hz Dry F.O.(Min 60 Hz Wet F.O.(Min CIFO + (Min. Withs CIFO - (Min. Withst	n. Withstand): stand):	453 kV 406 kV 778 kV 825 kV	(675 kV)	
	Specified Mech. Lo Routine Test Load (5,000 Lbs 2,500 Lbs	111.2 kN 55.6 kN	

BOLT — Ø0.75 [19]	1.6 [40]	
·		A
ł		
C-I		
B-		A

